MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
NARELA ZONE

No. DHO/NRZ/2026/D-228 Dated: 22/06/2026

SCHOOL HEALTH CERTIFICATE

Date of Inspection : **19.06.2026**

1. Name of School : **D.N. PUBLIC SCHOOL**
2. Address : **MAJRA DABAS NEW DELHI-110081**
3. No. of Shifts : **One Timing 08:00 AM to 02:00 PM**

Accommodation Provided

THE FLOOR AREA IN THE CLASSROOM IS **SUFFICIENT.**

THE CLASSES ARE **WELL LIGHTED.**

THE CLASSROOMS ARE **WELL VENTILATED**.

THE CLASSROOMS ARE KEPT **NEAT AND CLEAN.**

THE DRINKING WATER IS **WATER TEST REPORT APPROVED BY DJB LAB.**

THE TOILET ARRANGEMENT IS **SANITARY & HYGENIC AND SUFFICIENT IN NUMBER.**

Remarks :

THIS CERTIFICATE DOES NOT INDICATE PERMISSIBILITY FROM LAND POINT OF VIEW.

The certificate is valid for a period of one year from the date of issue.

22/6/26.
Dy. Health Officer
Narela Zone

Dy. Health Officer
Narela Zone

THE MANAGER

D.N. PUBLIC SCHOOL
MAJRA DABAS NEW DELHI-110081

Office of the A.C.W.A. Diary No. 72 Date 5/6/26 W.T.P. Bawana

DELHI JAL BOARD (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT BAWANA,
DELHI-110039.

SAVE WATER SAVE LIFE!

DATE: 05.06.2026

Water samples collected from D.N. Public School, Kh. No. 123 & 125, Budhanpur Majra Dabas Delhi-110081 vide Challan no. 81 Dated 26.05.2026.

S1:DJB Supply S2: Drinking Point in the premises after Filtration

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1	S2
			Acceptable	Permissible		
1.	Date of collection	--	---	---	30.05.2026	30.05.2026
2.	Date of Analysis	--	---	---	30.05.2026	30.05.2026
3.	Colour	C.U.	5	15	Clear	Clear
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U	1.0	5.0	1.95	1.11
6.	p^H value	--	6.5 to 8.5	N.R.	7.5	7.7
7.	Electrical Conductivity	µmhos/cm	----	-----	281.0	275.0
8.	Total Dissolved Solid	(mg/l)	500	2000	182.65	178.75
	CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	(mg/l)	----	----	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	76.0	74.0
11.	Total Hardness	(mg/l)	200	600	112.0	108.0
12.	Calcium Hardness	(mg/l)	---	---	76.0	70.0
13.	Magnesium Hardness	(mg/l)	---	---	36.0	38.0
14.	Calcium as Ca	(mg/l)	75	200	30.4	28.0
15.	Magnesium as mg	(mg/l)	30	100	8.64	9.12
16.	Ammonia (as NH_3-N)	(mg/l)	0.5	N.R.	ND	ND
17.	Nitrite –Nitrogen (N)	(mg/l)	---	---	ND	ND
18.	Nitrate (NO_3)	(mg/l)	45	N.R.	2.67	2.10
19.	Sulphate (SO_4)	(mg/l)	200	400	39.64	32.21
20.	Chloride (Cl)	(mg/l)	250	1000	10.0	9.0
21.	Iron (Fe)	(mg/l)	0.3	N.R.	0.04	0.03
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.25	0.22
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	Absent	Absent
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.40	0.25
	BACTERIOLOGICAL EXAMINATION					
25.	Coli form per 100 ml at 37^0C	MPN/100 mL	0		0	0

Remarks: As per above tested parameters, Both Samples S1 and S2 found satisfactory and can be used for drinking purpose.

Asst. Chemist/ Asst.Bacteriologist

Chemist/Bacteriologist

A.C.W.A. (Bawana)
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Bawana, Delhi-39